



MLGW
SERVING YOU IS
WHAT WE DO

MLGW Water System Status

System Status



Total Water Supply Demand

02/15/21	136,950,000
02/16/21	154,870,000
02/17/21	158,390,000
02/18/21	163,590,000
02/19/21	165,200,000
02/20/21	170,650,000
02/21/21	176,400,000
02/22/21	172,870,000
02/23/21	155,980,000
02/24/21	142,010,000
02/25/21	137,370,000
02/26/21	128,420,000
02/27/21	129,250,000
02/28/21	126,670,000

Declaration Started 2/15/21

Dashboard Last Updated

3/1/21 11:30 am

Water Supply Demand Daily Average

151,330,000

Daily Average

106,486,000

Normal Daily Average

Total Ruptured Mains

156

Ruptured Main Summary

140


16

Ruptured Mains Not Completed

Ruptured Mains Completed

Number of Ruptured Mains Repaired

02/15/21	2
02/16/21	8
02/17/21	6
02/18/21	15
02/19/21	10
02/20/21	18
02/21/21	9
02/22/21	21
02/23/21	16
02/24/21	15
02/25/21	11
02/26/21	6
02/27/21	2
02/28/21	1



Wells Operational

99

% Operational Wells

74%

Wells Status

35

99

Total Wells Out of service

Wells Operational

Water Pumping Station Status

Prior Day Status	Current Status	Station
		Mallory
		Sheahan
		Allen
		McCord
		Palmer
		Lichterman
		Morton
		Davis
		Shaw

Total Cut Offs

5,894

Information Below Contains The Following

- Cut Offs Broken Services

- Cut Offs Frozen Services

- No Water Call

Water Crisis Cut Offs

02/15/21	60
02/16/21	304
02/17/21	581
02/18/21	711
02/19/21	639
02/20/21	501
02/21/21	434
02/22/21	624
02/23/21	570
02/24/21	641
02/25/21	502
02/26/21	243
02/27/21	59
02/28/21	25